





CLEANING INSTRUCTIONS



USES

To clean out spill buckets, dispenser sumps and other subsurface contaminant systems.

FREQUENCY

Spill buckets should be kept clean and dry at all times. Inspect daily, clean as necessary. Follow company and regulatory guidelines to ensure buckets are inspected and cleaned regularly.

TASK DURATION

Depends on amount of liquid present. Usually 1 to 3 minutes per spill bucket.

TO CLEAN

1. For personal safety, place safety cones around spill bucket area. It is recommended to wear a safety vest.
2. Remove spill bucket cover with flathead screwdriver and set aside. Inspect spill bucket. If more than a 1/2 inch of liquid is present, use SUMPUR Pump to remove. Otherwise proceed to step 4.
3. Place SUMPUR Pump into spill bucket. Place discharge hose in SUMPUR Bucket. Raise and lower pump handle to remove liquid.*
4. Use SUMPUR Stick and BOOST HD® Pads to soak up remaining liquid.*

*Follow store policy and procedure to dispose of pads and liquids.



HAVE QUESTIONS? NEED TRAINING?
WE'RE HERE TO HELP!



Visit www.mycaf.com for additional product information, training materials, videos and more.

